

RECEIVED
VERNON TOWN CLERK
11 MAR 29 AM 10:57

The Bolton Lakes Regional Water Pollution Control Authority (BLRWPCA) held a public hearing on March 15, 2011 at the Town Hall with Chair Robert Morra presiding. Also in attendance were: board members Richard Hayes, Carmen Pellegrino, Daniel Wright, and Michael Morris; alternate Joyce Stille; Marshall Gaston, Fuss & O'Neill; and Bolton town resident Carl Preuss.

Mr. Morra called the hearing to order and read the legal notice (Attachment A).

Mr. Preuss asked about the project flow anticipated and any future capacity.
Mr. Morra and Mr. Gaston explained that the anticipated flow is 200,000 gallons per day. The lines put in are three times greater in size due to need to peak factor consideration. There is also a reserve of 75,000 EDU's for future flow.
Mr. Preuss inquired about some of EDU assignments and how they were determined, such as homes versus apartments or health clubs.
Mr. Morra, Mr. Hayes and Mr. Gaston responded. The baseline set is the average household use is 200 gallons per day or one EDU. Being a household, an apartment is one EDU. Since households have wells, there is no ability to meter everybody. Health clubs are based on membership. The flows in the proposed policy are based on the Connecticut health code.

Mr. Morra closed the hearing at 7:15 P.M.

Respectfully submitted,

Joyce M. Stille
Alternate, Bolton Lakes Regional Water Pollution Control Authority

PLEASE SEE THE MINUTES OF SUBSEQUENT MEEINGS FOR THE APPROVAL OF THESE MINUTES AND ANY CORRECTIONS HERETO.