

TOWN OF VERNON

Request for Proposals #1056-10/10/2014

*Masonry Repairs to Lucina Memorial Chapel in Grove Hill Cemetery
Cemetery Avenue, Vernon CT*

Notes from the Walk Through

QUESTIONS	ANSWERS
1. Do all the stones on the bell tower need to be removed and reset or just repointed?	No, only those needed to be made secure and safe.
2. Should all of the front (west) wall be repointed?	Yes, all of the rubble stone needs to be listed under bed proposal item 2B.
3. Does the efflorescence need to be included in this proposal?	No.
4.	
5.	
6.	
7.	
8.	
9.	
10.	
11.	
12.	
13.	
14.	
15.	
16.	
17.	
18.	
19.	
20.	
21.	