

Server Room Cooling Solution

Contract # 1066

Questions and Answers

Will this system be running year-round?

Yes, this cooling system will be running year-round, and as such will need to be able to function with both low and high outside ambient temperatures.

What efficiency rating is required?

A minimum SEER rating of 13 is required.

What type of unit must this be?

The specified unit is a wall-mount split ductless system, however alternative configurations can be quoted separately.

Is the vendor required to run new electrical circuits?

No, the Town will supply power to the demarcation point.

Will the vendor be required to obtain permits?

Yes, it will be the vendor's responsibility to obtain any required permits, but they will be paid for by the Town.

Can the condensers be mounted on the exterior wall?

Yes, they can be mounted on the exterior wall, at a minimum height of 11 ft.

Will this system need to be wired to an EPO switch?

No, there is no current requirement for this.