

Rockville High School Drainage

Addendum #1

Issued April 8, 2019

The Mandatory Site Walk Sign-in Sheet as provided herein is made part of the project. Only firms represented at that Site Walk may submit proposals for this Assignment.

Questions directed to the Town Engineer regarding the plans, specifications and/or field conditions – ***Answers provided in bold italics font***

1. The paved path access to the site, We noticed it was crumbling, can it withstand triaxle use? Who is responsible for the repair? ***The paved path serves the school and recreation program by providing access for pickups, mowing machines, etc. It is unlikely that it was designed to traditional roadway specifications. If damage to this paved surface is the result of the equipment and/or heavy vehicle traffic, the selected contractor shall not be responsible for restoring this to its current condition. All other damage to lawn areas, fencing and other features currently in place shall be repaired/replace to the current or better condition. This includes removal of the temporary anti-tracking pad and restoration to lawn. Stone products used in the anti-tracking pad may be disposed of on-site as directed by the Town Engineer.***
2. Does the town of Vernon have a disposal area that can be utilized for contractors for the wood debris? ***No.***
3. Will fill or topsoil need to be brought in or can we utilize what is onsite? ***The contractor shall reserve existing topsoil/ loam material as practical for reuse onsite and/or provide additional material to complete the final grading and restoration. No additional costs to the project will be allowed for imported material. With regard to fill material, the final grades and extent of disturbance are provided as guides, but can be adjusted with concurrence of the Town Engineer to provide for excess or shortfall of native material. No additional costs to the project will be allowed for these adjustments.***

The date and time for submissions remains unchanged. Two (2) copies of the proposal must be submitted in a sealed envelope, clearly marked "PROPOSAL DOCUMENT DO NOT OPEN Contract # 2050 - 2019/4/11" delivered to Michael J. Purcaro, Town Administrator, 14 Park Place Vernon, CT 06066 no later than 11:00 a.m. on April 11, 2019, at which time proposals shall be opened and read aloud publically. Emailed, faxed, or late proposals will not be accepted.

Rockville High School Drainage Improvements
Mandatory Pre-Bid Walk Through
March 27, 2019

Name JACKIE Koss Representing Koss Construction LLC
Address 170 Carl's Blvd
Phone 860 933-4557 Email KossConstructionLLC@gmail.com

Name Charles Pike Representing B&W Paving & Landscaping
Address 70 Foster Rd Waterford CT 06385
Phone 860-572-9942 Email betty@bandpaving.com

Name PAUL Ferreira Representing Flouthera Assoc.
Address 965 TRUMBULL HWY LEBANON CT 06249
Phone 860-886-3419 Email pdfcon@aol.com

Name Brian Gumbitz Representing N.E. BUTLER CON
Address 484 BARTMAN GSH RD BARTMAN CT 06180
Phone 860 342-3280 Email BG@NBUTLERCONSTRUCTION.COM

Name VALERIA VYVALEK Representing VYVALEK CON & CO.
Address 827 HIGHWAY RD.
Phone 860-301-2694 Email VYVALEKCONSTRUCTIONINC@gmail.com

Name John Cilly Representing Earth Dynamics
Address 116 Jean Circle Country
Phone 860-966-1362 Email earthdynamicsllc@gmail.com

Name Ryan Ackell Representing Priority Landscaping
Address 258 Whiston Rd Brookfield, CT
Phone 203-770-8278 Email prioritylandscapingllc@gmail.com

Name Evan Gerber Representing Gerber Construction
Address 1 Nudmer Dr Ellington
Phone 860 604 7548 Email evan@gerberconstructioninc.com

Name Brandon Phelps Representing Clover Construction
Address 7 Salem Lane Bristol CT
Phone 860 535 6227 Email cloverconstruction@comcast.net

Name Andy PALKER Representing PALKER EXC.
Address 112 Wellington St
Phone HARTFORD 06104 Email PALKEREXC@YAHOO.COM
860-309-6678

Rockville High School Drainage Improvements
Mandatory Pre-Bid Walk Through
March 27, 2019

Name John Holden Representing Holden Construction
Address Po Box 357 Ellington, CT. 06029
Phone 860-778-9152 Email HoldenConstruction007@gmail.com

Name Lynn Fabricio Representing VMS Construction
Address 112 Lake St. Vernon CT
Phone 860-871-0278 Email VMS@VMSCC.com

Name John Olender Jr. Representing John Olender Corp.
Address 23 Industrial Park Road East Tolland, CT. 06084
Phone 860-875-7803 Email johnjr-joc@skglobal.net

Name Vincent Genovesi Representing Genovesi Construction
Address Po box 408. Tolland, CT
Phone 860-810-6107 Email Vincent@genovesiconstructionllc.com

Name Scott Hines Representing Schumack Const
Address 93A Glendood Rd Clinton CT
Phone 860-669-7115 Email SHines@schumackconstruction.com

Name _____ Representing _____
Address _____
Phone _____ Email _____

Name _____ Representing _____
Address _____
Phone _____ Email _____

Name _____ Representing _____
Address _____
Phone _____ Email _____

Name _____ Representing _____
Address _____
Phone _____ Email _____

Name _____ Representing _____
Address _____
Phone _____ Email _____